

MIHAN DEPOT

SL NO	DESCRIPTION	Cable size
1	MDB - REPAIR BAY (Ground Floor)	2 x 3.5C 400 sq mm
	Incoming : 630 Amp	
	One Bi-Directuional MFM integral type Digital Electronic energy meter with suitable CTs	
	700 amps TPN copper bus bars with heat shrinkable insulation sleeves.	
	Out Going	
	400 amps TPN MCCB 2 Nos (1 No. for Solar)	
	250 amps TPN MCCB 2 Nos (1 No. for Solar)	
2	MDB - HVAC (Ground Floor)	1 x 3.5C 400 sq mm
	Incoming :	
	630 amps TPN MCCB with following accessories.	
	One Bi-Directuional MFM integral type Digital Electronic energy meter with suitable CTs	
	Out Going	
	400 amps TPN MCCB 2 Nos (1 No. for Solar)	
	100 amps TPN MCCB 4 Nos (2 No. for Solar)	
3	MDB - VENTILATION (Basement)	1 x 3.5C 400 sq mm
	Incoming :	
	630 amps TPN MCCB with following accessories.	
	One Bi-Directuional MFM integral type Digital Electronic energy meter with suitable CTs	
	Out Going	
	400 amps TPN MCCB 2 Nos (1 No. for Solar)	
	100 amps TPN MCCB 4 Nos (2 No. for Solar)	
4	MDB -Insp Bay (Ground Floor)	1 x 3.5C 300 sq mm
	Incoming :	
	400 amps TPN MCCB	
	Out Going	
	100 amps TPN MCCB 1 Nos (1 No. for Solar)	
5	MDB -Aux Rep Bay (Ground Floor)	1 x 3.5C 185 sq mm
	Incoming :	
	250 amps TPN MCCB	
	Out Going	
	100 amps TPN MCCB 1 Nos (1 No. for Solar)	

HINGNA DEPOT

Annexure-1 B

SL NO	DESCRIPTION	Cable size
1	MDB - REPAIR BAY (Ground Floor)	1 x 3.5C 400 sq mm
	Incoming : 630 Amp	
	One Bi-Directuional MFM integral type Digital Electronic energy meter with suitable CTs	
	700 amps TPN copper bus bars with heat shrinkable insulation sleeves.	
	Out Going	
	400 amps TPN MCCB 2 Nos (1 No. for Solar)	
	250 amps TPN MCCB 2 Nos (1 No. for Solar)	
2	MDB - HVAC (Ground Floor)	1 x 3.5C 400 sq mm
	Incoming :	
	630 amps TPN MCCB with following accessories.	
	One Bi-Directuional MFM integral type Digital Electronic energy meter with suitable CTs	
	Out Going	
	400 amps TPN MCCB 2 Nos (1 No. for Solar)	
	250 amps TPN MCCB 2 Nos (1 No. for Solar)	
3	MDB - Insp Bay (Ground Floor)	1 x 3.5C 300 sq mm
	Incoming :	
	400 amps TPN MCCB with following accessories.	
	Out Going	
	200 amps TPN MCCB 2 Nos (1 No. for Solar)	
	63 amps TPN MCCB 2 Nos (1 No. for Solar)	
4	MDB - Aux Rep Bay (Ground Floor)	1 x 3.5C 150 sq mm
	Incoming :	
	400 amps TPN MCCB with following accessories.	
	Out Going	
	100 amps TPN MCCB 1 Nos (1 No. for Solar)	
	63 amps TPN MCCB 3 Nos (1 No. for Solar)	
5	Main LT Panel	
	Incoming 4000 Amp	
	Outgoing:	
	400 amps TPN MCCB 2 Nos (1 No. for Solar)	