

CORRIGENDUM-II

PR- BID Quarries 27/07/2016

Name of Work: Shifting of LT,HT O/H line ,crossings and providing LT,HT U/G cables from Lad square (CH:10750) to Munje Chowk (CH:7743) for Nagpur Metro Rail Project for E-W Corridor.


Tender No. : - N1-(U/S)/(ELE)/08-2016 (2nd Call) Dated 15/07/2016

Portal No:-55

Dated:03/08/2016

Sr.No	Description	Quarries	Clarifications
1	Tender Schedule	Last Date of Submission of Bid 16:00 hrs on 07/08/2016 Date of opening of Bid 17:00 hrs on 07/08/2016	Revised As 16:00 hrs on 11/08/2016 Revised As 17:00 hrs on 11/08/2016
2		We request you to allow us to participate in tender joint venture/consortium for the same	Revised Eligibility Criteria for sole bidder and JV/Consortium is at Annexure-I
3		As per CVC guideline notice no.12-02-1CTE-6 dated: 17/Dec/2002 page no.3 " Average annual financial turnover during the last 3 years , ending 31 march of the previous financial year, should be at least 30% of the estimated cost ". It should be 62.63 lacs.	Refer Annexure-I Annexure-IV i. Form of Joint Bidding Agreement. ii. Form of Legal Capacity / Power of Attorney. iii. Power of Attorney for signing of Bid. iv. Power of Attorney for Lead Member of Consortium.
4		We request you to allow single order of one Cr.	Refer Annexure-I
5		We are registered with national small industries corporation(NSIC).We were already taking exemption against the attached NSIC Certificate .kindly	Not accepted
6		Electrical Speciation not available in Tender	Electrical Speciation is at Annexure-III
7		Electrical Approved Make LIST not given in Tender	Electrical Approved Make LIST is provided in Annexure-III
8		Please send specification of MSEDCL	As above
a	1)Supplying, erecting & terminating 3 x300 sq mm 11 KV, XLPE(E) round armoured cable to be laid in trench / pipe in an approved manner as per specification No CB-HT or latest.	Cable Laying in Ready Made Trench?	Item includes excavation and refilling of trenches.
b	2)Supplying, erecting & terminating 3 x300 sq mm 33 KV, XLPE(E) round	Cable Laying in Ready Made Trench?	Item includes excavation refilling of trenches.

	armoured cable to be laid in trench /pipe in an approved manner as per Specification No CB-HT or latest.		
c	3)Supplying, erecting & terminating PVC armoured cable 3½ core 185 sq mm aluminum conductor with continuous 12.97 sq mm (8 SWG) G.I. earth wire complete with glands & lugs, on pole or laid in trench/ pipe as per specification no. CB-LT/AL or latest.	Laying in Ready Made Trench or Pole?	Work has to be carried as per specification no SS-AS/FSG or latest.
d	15)Supplying and erecting fencing of section having size 2450 mm in height from ground level and 1200 mm width with angle iron frame work erected in C foundation and painted as per specification No SS-AS/FSG or latest.	Pls specify qty in Mtr.	Work has to be carried as per specification no SS-AS/FSG or latest.
e	16)Supplying and erecting 50 x 50 x 6mm. angle iron as corner support 2m long fixed at the middle of the fencing frame and the other side inclined at 30 degree angle, in C.C. foundation of 15x 15 x 40cm complete duly painted with one coat of red oxide and two coats of aluminum paint.	Pls specify qty in nos.	Work has to be carried as per specification no SS-AS/FSG or latest.
f	23)Dismantling existing pole mounted Distribution Transformer safety Without any damages and storing it in safe place.	Rate submit in per kva ? Qty given in 2 kva. Kindly confirm.	Corrected BOQ attached. Annexure-II


 General Manager (Proc.)
 MMRCL, Nagpur