

Nagpur Metro Rail Corporation Limited (NMRCL)

Tender No. N1C-04/2016

Name of Work: CONSTRUCTION OF SEVEN ELEVATED METRO STATIONS AND THREE AT GRADE STATIONS (NORTH SOUTH CORRIDOR) VIZ. CONGRESS NAGAR TO KHAPRI AND VIADUCTS BETWEEN CH:7/850 TO 8/030 AND CH:8/574 TO 9/692 IN REACH-1.

Corrigendum VIII

Date: 03/05/2016

Tender No. (As uploaded in the E-Tender Portal): - No. 32

MEP WORKS ADDENDUM/CORRIGENDUM Materials and Specifications						
S.No	Tender Document Reference				Original	Corrigendum To be read as
	Part	Section	Item/Chapter	Clause		
1	II , Works Requirement	VII B, Particular Specification-Electrical and HVAC	Sec-H, Uninterrupted Power Supply System	Clause No 9.4.2	System features	SLD of required UPS System given to understand the scheme
				Clause No 9.4.4	Static PWM Convertor	Isolation transformer required at input of UPS
				Clause No 9.4.5	Nominal voltage output 240V, 3-phase	Output voltage shall be 1-phase (240 Volt)
				Clause No 9.5	Battery System	Battery Shall be 2V SMF VRLA battery
2	II , Works Requirement	VII B, Particular Specification-Electrical and HVAC	10, Building Management System	General	SLD & I/O List	BMS Single line Diagram along with tentative I/O List given to understand system requirement
					BMS System	General Purpose PLC

3	II, Works Requirement	VII B, Particular Specification-FACP	Fire Annunciation System	General	System Compliance	The system shall comply NFPA/BS.
					Standards, Codes and Regulations	The UL/EN for the Fire Detection and Alarm system
					Standards, Codes and Regulations	The equivalent or similar feature to be considered by bidders as per NFPA/BS as mentioned in the specification
					Approval/Certification	MCP shall be approved from UL/LPCB (Loss Prevention Certification Board) as mentioned in the specification



**General Manager,
(Procurement),
NMRCL, Nagpur**